შენობა-ნაგებობის უსაფრთხოების წესებთან შესაბამისობის ანალიზი

გამოყენებული წესები - **„შენობა-ნაგებობის უსაფრთხოების წესები“**

ჩამოთვალეთ შენობის დაკავებულებები და აღწერეთ თითოეული გამოყენება
1. სასაწყობე ჯგუფი სწ-2 (ავტოსადგომი,) 4 სართული (-3.00; 0,00;+3.00+6.00 ნიშნულებზე)
2. საქმიანი ჯგუფი სქ (ხანძრის მართვის ცენტრი 0,00 ნიშნული)
3. საცხოვრებელი ჯგუფი სც-2(საცხოვრებელი ბინები 31 სართული) IV -დან XXXIსართულის ჩათვლით (+9,00 ნიშნულიდან +94,05 ნიშნულის ჩათვლით)
4. დამხმარე ჯგუფი დს(ტექნიკური ოთახი; რეზერვუარი, სატუმბოს ოთახი,) 0.00 ნიშნულზე

კონსტრუქციის ტიპი:	
განსაზღვრეთ კონსტრუქციის არსებული შენობისთვის: მაგალითი: II-A, II-B, V-A, V-B	
განსაზღვრეთ კონსტრუქციის ტიპი ახალი შენობისთვის: მაგალითი: II-A, II-B, V-A, V-B	I-A მიწის დონის ზემოთ I-A მიწის დონის ქვემოთ
შერეული კონსტრუქციის შემთხვევაში მიუთითეთ ტიპები, რომელიც გამოყენებული იქნება, განსაზღვრეთ ტიპები და მათი მდებარეობა:	

სიმაღლის შეზღუდვები ცხრილი 503 -ის მიხედვით		
დაკავებულობები	**დასაშვები სართულიანობა**	**შემოთავაზებული სართულიანობა**
1. სასაწყობე ჯგუფი სწ-2	**შეუზღუდავი**	**4 სართული**
2. საქმიანი ჯგუფი სქ	**შეუზღუდავი**	**1 სართულზე**
3. საცხოვრებელი ჯგუფი სც-2	**შეუზღუდავი**	**28 სართული**
4. დამხმარე ჯგუფი დს	**შეუზღუდავი**	**1 სართული**
	დასაშვები სიმაღლე	**შემოთავაზებული სიმაღლე**
შენობის სიმაღლე =	**შეუზღუდავი**	**101.88 მ.**
მიწის დონის ზემოთ სართულ(ებ)ის რაოდენობა =	**შეუზღუდავი**	**31** (აქედან 1მიწისქვეშა სართული)

ფართობის შეზღუდვები ცხრილი 503 -ის მიხედვით		
დაკავებულობები	**დასაშვები ფართობი (სართულზე)**	**შემოთავაზებული ფართობი (სართულზე)**
1. სასაწყობე ჯგუფი სწ-2 (-1 სართული)	**შეუზღუდავი**	2450.4 მ² (-3,00 ნიშნულზე)
2. სასაწყობე ჯგუფი სწ-2 (1 სართული)	**შეუზღუდავი**	2111.1 მ² (0,00 ნიშნულზე)
3. სასაწყობე ჯგუფი სწ-2 (2 სართული)	**შეუზღუდავი**	2461.8 მ² (+3.00 ნიშნულზე)
4. სასაწყობე ჯგუფი სწ-2 (3 სართული)	**შეუზღუდავი**	2461.8 მ² (+6,00 ნიშნულზე)
5. საქმიანი ჯგუფი სქ (1 სართული)	**შეუზღუდავი**	19.7 მ² (0,00 ნიშნულზე)
6. დამხმარე ჯგუფი დს (1 სართული)	**შეუზღუდავი**	220.9 ,მ² (0,00 ნიშნულზე)
7. საცხოვრებელი ჯგუფი სც-2 (4-31 სართული)	**შეუზღუდავი**	29031.5 მ² (+9.00 - -+94.05 ნიშნულზე)
შემოთავაზებული ფართობების ჯამი =	**38757.2 მ²**	
სართულების რაოდენობა =	**32**	
შენობის საერთო ფართობი =	**48293.7 მ²**	

გარე კედლის ცეცხლმედეგობისა და ღიობისადმი მოთხოვნები ცხრილების 602-ის და 705.8 -ის მიხედვით									
გარე კედელი	**ხანძარსაწინააღმდეგო მანძილი** (მეტრი)	**ცეცხლმედეგობის ხარისხი** (საათი)		**კედლის ღიობების ფართობი** (კედლის %)					
		მოთხოვნილი	**გათვალისწინებული**	**დასაშვები**			**გათვალისწინებული**		
				დაცული	**დაუცველი საშხეფებით**	**დაუცველი**	**დაცული**	**დაუცველი საშხეფებით სწ-2**	**დაუცველი სწ-2/სც-2**
A'-Q	9<	0	0.4	**არ მოეთხოვება**	**არ მოეთხოვება**	**შეუზღუდავი**		აკმაყოფილებს	აკმაყოფილებს
Q-A'	წარმოსახვითი საზღვარი 6,93მ, ყრუ ფასადი +8,90-დან	0	3/4	**შეუზღუდავი**	**შეუზღუდავი**	**45%/შეუზღუდავი**		აკმაყოფილებს	აკმაყოფილებს/ სც-2 ყრუ ფასადი, სწ-2 6,14% ღია
1'-7	9<	0	0/3/4	**არ მოეთხოვება**	**არ მოეთხოვება**	**შეუზღუდავი**		აკმაყოფილებს	აკმაყოფილებს
7-1'	9<	0	0/4	**არ მოეთხოვება**	**არ მოეთხოვება**	**შეუზღუდავი**		აკმაყოფილებს	აკმაყოფილებს

ხანძრისაგან დაცვის სისტემებისადმი მოთხოვნები							
დაკავებულობები/სივრცეები/გასასვლელი საშუალებები	**ავტოსაშხეფი სისტემა**	**ალტერნატიული ავტომატური**	**სახანძრო განგაშისა, კვამლაღმომჩე**	**სახანძრო მილდგარების სისტემები**	**კვამლის საკონტროლო სისტემები**	**ხელის ცეცხლმაქრები**	**საავარიო განგაშის სისტემები**

		ცეცხლსაქრობი სისტემები	ნი და ცეცხლაღმომჩე ნი სისტემები				
1.სასაწყობე ჯგუფი სწ-2 (ავტოსადგომი) -3,00/0,00; ნიშნულზე	კი		კი	კი სახანძრო კარადა	კი (მექნიკური განიავების სისტემით)	კი	-
1.სასაწყობე ჯგუფი სწ-2 (ავტოსადგომი) +3,00 და +6,00 ნიშნულებზე			კი	კი (სახანძრო კარადა)	კი ბუნებრივი	კი	-
2.საცხოვრებელი ჯგუფი სც-2 VI სართულიდან XXVIსართულის ჩათვლით			კიკვამლზე მორეაგირე მაუწყებელი სამინებელში				
კიბის უჯრედი			კი	კი	კი (გზა-კიბე და ვესტიბიული დაწნევის სისტემით)		
ლიფტები			კი		კი (ლიფტებისშა ხტა დაფოიე დაწნევის სისტემით)		
დერეფანი	კი		კი	კი (სახანძრო კარადები)	კი (მექნიკური განიავების სისტემით)	კი	
სახანძრო-სამაშველო სამსახურის მიერ გამოსაყენებელი მისაერთებლები				კი			
სახანძრო ტუმბოები და წყლის რეზერვუარი (-3.00ნიშნულზე)				კი			

განიავებისადმი მოთხოვნები		
დაკავებულობები/სივრცეები/გასასვლელი საშუალებები	ბუნებრივი განიავება	ხელოვნური განიავება
სასაწყობო ჯგუფი სწ-2 (-3.00; ნიშნულზე ავტოსადგომი)	-	კი
სასაწყობო ჯგუფი სწ-2 (ავტოსადგომი+3,00 ; 0.00, +6.00)	კი	
საცხოვრებელი ჯგუფი სც-2 (ბინები)	კი	კი
კიბის უჯრედი	-	კი

ლიფტები	-	კი
დერეფანი	-	კი

თითოეული სართულიდან გასასვლელი საშუალება									
სართულები	დაკავებულობა და დაკავებულობის დატვირთვის ჯამური მაჩვენებელი	მოთხოვნილი გასასვლელების/გასასვლელთან მისადგომის რაოდენობა	გათვალისწინებული გასასვლელების/გასასვლელთან მისადგომის რაოდენობა და ტიპი	გასასვლელი საშუალებების სიგანე(მეტრი)					
				გზა-კიბეები		დერაფანი,		გასასვლელის გზა-კარი	
				მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული
4 სართული	სწ-2 ჯამური დ.დ- 510	2	2	1.10 მ.	1.25 მ.	1.20 მ.	120/1.65	82 სმ.	82 სმ.
1 სართული	სქ დ.დ- 1	1	1					82 სმ.	82 სმ.
2 სართული	დს დ.დ- 4	1	1					82 სმ.	82 სმ.
23 სართული	სც-2 ჯამური დ.დ 1561	2	2	1.10 მ.	1.25 მ.	1.20 მ.	1.25/165 მ.	82 სმ.	82 სმ.

წყალსადენი სისტემის ფიქსირებული მოწყობილობების რაოდენობა ცხრილი 1602.1-ის მიხედვით													
სართულები	დაკავებულობა და დაკავებულობის დატვირთვის ჯამური მაჩვენებელი	ფიქსირებული მოწყობილობები(ცალი)											
		უნიტაზი		ტუალეტის ხელსაბანები		აბაზანა/შხაპი		სასმელი წყლის ფანტანი		სამომსახურეო ნიჟარა		სამზარეულოს ნიჟარა	
		მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული	მოთხოვნილი	გათვალისწინებული
4 სართული	სწ-2 დ.დ- 508	-	-	-	-	-	-	-	-	-	-	-	-
1 სართული	სქ დ.დ- 2	-	-	-	-	-	-	-	-	-	-	-	-
1 სართული	დს დ.დ- 8	-	-	-	-	-	-	-	-	-	-	-	-
28 სართული(ერთ ერთეულზე)	სც-2 (დ.დ)	1	1	1	1	1	1					1	1

გამოყენებულული პირობითი აღნიშვნები

	გასასვლის ნიშნები	
	კედლის ავარიული განათება	დერეფანი, კარ.კიბე, ვენტილიატორი, ფოიე, ავტოსადგომი, საპირმე, ლიფტის სახმარები
	ჭერის ავარიული განათება	დერეფანი, კარ.კიბე, ვენტილიატორი, ფოიე, ავტოსადგომი, საპირმე, ლიფტის სახმარები
	კვადრატშხრეში	(907.2.13.1.1)
	კვადრატ მორგაცარე მილსწყვილი	(907.2.11.2)
	ავტომაშხეი	(903)
	ავტეტრანსფორმატორი ავტომატური ელექტრომრთველი სისტემა	(904) საერთაშორისო ტარო. საკუთრი. მეცნიერული მოწყობილობების ოთახებში და სამრხეტე ოთახებში
	კვადრატ დეტექტორიში ინტეგრირებული სირენა	პორიზონტალ სამრხეტლებში ცენტრში მამაღლებით
	ფიქსირებ სისტემა	909.20.5 -909.21 ტუნელე, ვენტილიატორი, ღიობების მიხეი და ფოიე
	წყლის ფიზიკური მიმრეველი	
	ჰიდრანტი	
	სახანძრო მილსწყვარი	905 მეთრამდე. რიგიანი ფაცილებული ოდნავ არ მცირდებოდს სახანძრო სისტემის მისაწვდომი ელექტრო ფანელით დიამეტრის 8 მ-მდე ზედმიწევნით ძირითადად და კარადა არ მოეთხოვება)
	სახანძრო კარადა	მეთრამდე. რიგიანი ფაცილებული ოდნავ არ მცირდებოდს სახანძრო სისტემის მისაწვდომი ელექტრო ფანელით დიამეტრის 8 მ-მდე ზედმიწევნით ძირითადად და კარადა არ მოეთხოვება)
	ხელის ელექტრსისტო	906
	ჭეშ-კიბის საკომუნიკაციო სისტემა	403.5.3.1
	მისაწვდომის საერთაშორისო სიმბოლო	
	სახანძრო მისაცრეველი	
	სახანძრო სისტემული დაშვებადობის მისაცემი ლიფტის სიმბოლო	1707.7.5
	სახანძრო განგაშიტებისთვის ელემენტის სისტემა	907.2.13.2
	სახანძრო განგაშის ხელით სამოქმედო სისტემა	
	დაწვეთებით შეტყობინება "სარემონტო/ნაწილობრივ" (Strobe) მაგალითი ხმოვანი განგაშის საკომუნიკაციო სისტემა და მრეველექტრონიკა განგაში	907.2.9.1; 907.4.2.1
	შიბრი მექანიკური განიავება (ავტომატიკურად დეტექტორით პარკინგში	
	მექანიკური განიავება (საკონტროლო დეტექტორი პარკინგში	
	ხელმისაწვდომი განიავება	
	სახანძრო შესასვლელი ღიობებით არ ისარგებლოთ	
	სამრხეთო სახელფიანი დამხმარეთის საერთაშორისო სიმბოლო	
	მიმეული. მოსაწვლე დამხმარე სისტემისთვის	
	ევაკუაციისმე ზიმა (30-60წთ)	
	ევაკუაციისმე პანელი (60წთ)	

მასშტაბით სულ-ვეზე Fill Pen 82



მასშტაბით სულ-ვეზე სართულებზე სიერეები Fill Pen 82



სიფრქნელი ბიღეკი Fill Pen 108



ეკლეკი მოსარგებე პირის აღმნიშვნელი სიმბოლი



ესკიზირი ზომა 1300X760მმ RGB (153,153,153)



მმ აღნიშნული სიმბოლი სულ ნეზტატიან.



სულის მიმდინარ აღნიშვნა



ევაკუაციისმის სარისხის აღნიშვნა

ფაცალელობის ჯგუფები

სგ2	საპოლიტიკო ფაცალელობის ჯგუფი - **სგ2** RGB (255,255,0)
სწ2	სასწორი ფაცალელობის ჯგუფი - **სწ2** RGB (136,135,134)
სქ	სამრხი ჯგუფი - **სქ** RGB (79,12,187)
სვ	სავერო ფაცალელობის ჯგუფი - **სვ** RGB (255,0,0)
ფწ	ფიზიკრელეობით ჯგუფი - **ფწ** RGB (0,0,255)
სმ	სამოქალო ჯგუფი - **სმ** RGB (160,32,240)
სგ	სავაჭროსალო ჯგუფი - **სგ** RGB (240,99,20)
დსმ	დიდი სავრხის შეზღუდული ჯგუფი - **დსმ** RGB (94,8,58)
დს	დამხმარე ჯგუფი - **დს** RGB (57,57,56)
თვ	თიხსერის ჯგუფი - **თვ** RGB (34,139,34)

ფაცალელობის აღმნიშვნელი

L63-2	18.6
⌀⌀	3

კედლის სავრცხელი სისტემების დიობი ფიდაში

"x" ტაბის სიმის აღნიშვნა სართულეი ჯგუფისე

ევაკუაციის მიზეი აღნიშვნა

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:



შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N :	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Coordination

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 50	A0	

ნახაზის N : | **რევ :**

GA-WYA-Site-MN301

სტატუსი :

WIP

N732-ე დადგენილების შესაბამისად პირობითი აღნიშვნების ფურცელი

მოსატრიალებელი სივრცეები



T - სოფრმის მოსატრიალებელი სივრცე 304.3.2.1. (ა) ვარიანტი 1



T - სოფრმის მოსატრიალებელი სივრცე 304.3.2.1. (ბ) ვარიანტი 2



წრიული მოსატრიალებელი სივრცე 304.3.1.1.

თავისუფალი სივრცე კართან მანევრირებისთვის



თავისუფალი სივრცე კართან მანევრირებისათვის -ანჯამიანი კარი -წინიდან მისაწვდომი -გამოწევით გაღება



თავისუფალი სივრცე კართან მანევრირებისათვის-ანჯამიანი კარიწინიდან მისაწვდომი მოწოლით გაღება



თავისუფალი სივრცე კართან მანევრირებისათვის -ანჯამიანი კარი -გვერდიდან მისაწვდომი -გამოწევით გაღება

თავისუფალი სივრცეები "ა" ტიპის მანევრირებისთვის



იატაკის თავისუფალი სივრცე "ა"ტიპის ერთეულებისთვის



ეტლის შესაგორებელი საშხაპის არმქონე ნაკეთურის თავისუფალი სივრცე



ეტლის შესაგორებელი საშხაპის მქონე ნაკეთურის თავისუფალი სივრცე



უნიტაზები ა ტიპის ერტეულებში თავისუფალი სივრცე ხელსაბანთან(გადაფარვა გამონაკლისი)



"ა" ტიპი უნიტაზთან მისადგომი თავისუფალი სივრცე



"ა" ტიპი ხელსაბანთან მისადგომი თავისუფალი სივრცე

თავისუფალი სივრცეები "ბ" ტიპის მანევრირებისთვის



სამოძრაო ბილიკი



იატაკის თავისუფალი სივრცე "ბ"ტიპის ერთეულებისთვის



"ბ" ტიპი თავისუფალი მანძილი უნიტაზთან



"ბ" ტიპი ხელსაბანთან მისადგომი თავისუფალი სივრცე



უნიტაზები ბ ტიპის ერტეულებში თავისუფალი სივრცე ხელსაბანთან გადაფარვა

1 BA-01-MN - მიწისქვეშა სართულის გეგმა

1 : 100


ჭრილი 7-7'
ჭრილი 1'-7
ჭრილი A'-Q
GA-WYA-EL_Q-A'-A-MN204
GA-WYA-EL_7'-7-A-MN202
GA-WYA-EL_A'-Q-A-MN203
GA-WYA-EL_1'-7-A-MN201
GA-WYA-BF_1-A-MN01
GA-WYA-BF_2-A-MN02
GA-WYA-BF_3-A-MN03
GA-WYA-BF_5-A-MN01
GA-WYA-BF_5-A-MN02
GA-WYA-EL_1'-7-A-MN205
80250
ბეტონის საყრდენი კედელი h=4.37 მ
ბეტონის საყრდენი კედელი h=3.41 მ
ბეტონის საყრდენი კედელი h=3.41 მ
ბეტონის საყრდენი კედელი h=5.41.38 მ
ბეტონის საყრდენი კედელი h=2.11 მ
ბეტონის საყრდენი კედელი h=90.17 მ
ბეტონის საყრდენი კედელი h=87.07 მ
ბეტონის საყრდენი კედელი h=86.10 მ
ბეტონის საყრდენი კედელი h=89.32 მ
ბეტონის საყრდენი კედელი h=26.27 მ
ბეტონის საყრდენი კედელი h=2.06 მ
საბანდაჟო ამონტაჟი
ტერასა
ტერასა
ტერასა

LV-01-MN

1 : 100

Revision	Date	Description	Issued by	Issued

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign-off prior to placement of Order, Fabrication or Construction.
2. Do not scale drawings. Use figured dimensions only.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371, Ria Chechnyadze
Tbilisi, Georgia, 0162, T bilisi, Georgia
info@wei-yap.com | www.wei-yap.com
Wei Yap Architects LLC
Identification Number : 405351555

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვორქე დადიანის ქ. #32

სათაური :

Level 1

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

LV-02-MN

1 : 100

Revision	Date	Description	Issued by	Issued

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale drawings, use figured dimensions only.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

ხაოფიციალიზაციო გვერდი :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371, Ria Chochiashvili
Batumi, Adjara, Georgia, 6010, T'bilisi, Georgia
info@wei-yap.com | www.wei-yap.com
Wei Yap Architects LLC
Identification Number : 405201555

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architects (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ზაქარია ფრანგიშვილი, ტოტე დადიანის ქ. #32

სათაური :

Level 2

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG
დახაზა :	
SP	

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-03-MN
1 : 100

Revision	Date	Description	Issued by	Issued

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale drawings, use figured dimensions only.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო ჩვენება :

შენიშვნა:

Wei Yap Architects
Office Space #4, Level 3, 371, Ria Chechnyadze Street, Avlabari, Tbilisi, 0102, T'bilisi, Georgia
info@wei-yap.com | www.wei-yap.com
Wei Yap Architects LLC
Identification Number : 405211111

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architects (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი & ბლოკი Project Address: ზაქარია ფირცხალა, ფოქუს დადიანის ქ. #32

სათაური :

Level 3

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-04-MN
1 : 100

ტერასა
1145.9 მ²

Revision	Date	Description	Issued by	Issued

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale drawings, use figured dimensions only.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო ჩრდილოეთი :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371, Rio Chochiashvili
Tbilisi, Georgia, 0162, 7 Tbilisi, Georgia
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number - 405231111

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architects(Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის №:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი

Project Address: ქალაქი თბილისი, გორგილა დადიანის ქ. #32

სათაური :

Level 4

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-04-ACC - მისაწვდომობის გეგმა - L04

1 : 100



Revision	Date	Description	Issued By	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 4

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-05-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 5

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-05-ACC - მისაწვდომობის გეგმა - L05-L09

1 : 100



GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

Revision	Date	Description	Issued by	Issued to

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 5

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-06-MN

1 : 100


ფასადი 7-1'
ფასადი 1'-7
ფასადი Q-A'
ფასადი A'-Q
GA-WYA-EL_7-1'-A-W1202
GA-WYA-EL_Q-A'-A-MN204
GA-WYA-EL_A'-Q-A-MN203
GA-WYA-MBS_3-3-A-MN303
GA-WYA-MBS_1-1-A-MN351
GA-WYA-MBS_1-1-A-MN301
GA-WYA-MBS_2-2-A-MN302
GA-WYA-EL_Q-A'-A-MN142
3 ტიპის ბინა #52
ბინა 36
ბინა 35
ბინა 52
ბინა 51
ბინა 50
ბინა 49
ბინა 48
ბინა 37
ბინა 38
ბინა 39
ბინა 40
ბინა 41
ბინა 42
ბინა 43
ბინა 44
ბინა 45
ბინა 46
ბინა 47
80250
31700
44700
8250
ბინის სიგრძე
კიბეებს შორის მანძილი
მანძილი საკაფასტრო სახაზვრამდე - 431.00 მ
მანძილი საკაფასტრო სახაზვრამდე - 541.37 მ
მანძილი საკაფასტრო სახაზვრამდე - 90.17 მ
მანძილი საკაფასტრო სახაზვრამდე - 87.07 მ
მანძილი საკაფასტრო სახაზვრამდე - 65.32 მ
მანძილი საკაფასტრო სახაზვრამდე - 86.10 მ
მანძილი საკაფასტრო სახაზვრამდე - 27.20 მ
მანძილი საკაფასტრო სახაზვრამდე - 206.06 მ
მანძილი წყვეთზე არსებული ხეღოვის მიწის ზედაპირის ნიშნულამდე - 84.72 მ
მანძილი წყვეთზე არსებული ხეღოვის მიწის ზედაპირის ნიშნულამდე - 32.15 მ
მანძილი წყვეთზე არსებული ხეღოვის მიწის ზედაპირის ნიშნულამდე - 38.27 მ
მანძილი წყვეთზე არსებული ხეღოვის მიწის ზედაპირის ნიშნულამდე - 84.64 მ
მანძილი წყვეთზე არსებული ხეღოვის მიწის ზედაპირის ნიშნულამდე - 84.64 მ
ნაგვისათვის ბუნკერის მოედანი 11.68 მ
სანაგვეზე ნაგვის ბუნკერის მოედანი 12.00 მ
სანაგვეზე ნაგვის ბუნკერის მოედანი 13.00 მ
ნაგვის ბუნკერის მოედანი 12.00 მ
ნაგვის ბუნკერის მოედანი 11.68 მ
ნაგვის ბუნკერის მოედანი 12.00 მ

1 LV-07-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო ვეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვორტე დადიანის ქ. #32

სათაური :

Level 7

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-08-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N: 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 8

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : 1 : 100

ფორმატი : A0

თარიღი :

ნახაზის N : GA-WYA-BF-01-A-2201

რევ :

სტატუსი : **WIP**

1 LV-09-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 9

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-10-MN

1 : 100


ფასადი 7-1`
ფასადი 1`-7
ფასადი Q-A`
ფასადი A`-Q
GA-WYA-EL_7-1`-A-W1202
GA-WYA-EL_A`-Q-A-MN203
GA-WYA-BS_3-3-A-MN303
GA-WYA-BS_1-1-A-MN301
GA-WYA-BS_2-2-A-MN302
GA-WYA-MHS_1-1-A-MN351
GA-WYA-MHS_1-1-A-MN146
GA-WYA-EL_Q-A`-A-MN204
ბინძილი საკანალიზაციო სიმაღლეზე - 90.17 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 87.07 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 65.32 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 86.10 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 87.18 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 206.06 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 431.00 მ
ბინძილი საკანალიზაციო სიმაღლეზე - 541.37 მ
ბინძილი წყალგრძივ კოლექტორზე ბილის სიმაღლეზე - 84.72 მ
ბინძილი წყალგრძივ კოლექტორზე ბილის სიმაღლეზე - 84.44 მ
წყალგრძივ ბლოკების გასწვრივ დაწნეხილი გრუნტის ბერმა
ბინძილი წყალგრძივ კოლექტორზე ბილის სიმაღლეზე - 38.27 მ
წყალგრძივ ბლოკების გასწვრივ დაწნეხილი გრუნტის ბერმა
ბინძილი წყალგრძივ კოლექტორზე ბილის სიმაღლეზე - 84.72 მ
წყალგრძივ ბლოკების გასწვრივ დაწნეხილი გრუნტის ბერმა
ბინძილი წყალგრძივ კოლექტორზე ბილის სიმაღლეზე - 38.27 მ
წყალგრძივ ბლოკების გასწვრივ დაწნეხილი გრუნტის ბერმა
ბინძილი წყალგრძივ კოლექტორზე ბილის სიმაღლეზე - 84.72

1 LV-10-ACC - მისაწვდომობის გეგმა - L10-L16

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვოტრე დადიანის ქ. #32

სათაური :

Level 10

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-11-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვოტრე დადიანის ქ. #32

სათაური :

Level 11

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-12-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო ვექტორი :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 12

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-13-MN

1 : 100

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:



Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვოკზე დადიანის ქ. #32

სათაური :

Level 13

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-14-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 14

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-15-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 15

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-16-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N: 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 16

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : 1 : 100

ფორმატი : A0

თარიღი :

ნახაზის N : GA-WYA-BF-01-A-2201

რევ :

სტატუსი : **WIP**

1 LV-17-MN
1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :
CLIENT NAME

პროექტის N: 0000X
პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :
Level 17

მთავარი არქიტექტორი : LM/WY
პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : 1 : 100
ფორმატი : A0
თარიღი :

ნახაზის N : GA-WYA-BF-01-A-2201
რევ :

სტატუსი :
WIP

1 LV-17-ACC - მისაწვდომობის გეგმა - L17

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

ოორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვოტრე დადიანის ქ. #32

სათაური :

Level 17

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-18-MN
1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :
CLIENT NAME

პროექტის N: 0000X
პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :
Level 18

მთავარი არქიტექტორი : LM/WY
პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : 1 : 100
ფორმატი : A0
თარიღი :

ნახაზის N : GA-WYA-BF-01-A-2201
რევ :

სტატუსი : **WIP**

1 LV-18-ACC - მისაწვდომობის გეგმა - L18-L25

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 18

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-19-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო ვექტორი :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 19

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-20-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 20

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-21-MN

1 : 100


ფასადი 7-1'
ფასადი 1'-7
ფასადი A'-Q
GA-WYA-EL_7-1'-A-W1202
GA-WYA-EL_A'-Q-A-MN203
GA-WYA-BS_3-3-A-MN303
GA-WYA-BS_1-1-A-MN351
GA-WYA-BS_1-1-A-MN301
GA-WYA-BS_2-2-A-MN302
GA-WYA-EL_Q-A'-A-MN204
80250
31700
14600
8200
ბინა 301
ბინა 302
ბინა 303
ბინა 304
ბინა 305
ბინა 306
ბინა 307
ბინა 308
ბინა 309
ბინა 310
ბინა 311
ბინა 312
ბინა 313
ბინა 314
ბინა 315
ბინა 316
ბინა 317
მაბინძრებელი საკანალიზაციო მილი Ø160 მმ
მაბინძრებელი საკანალიზაციო მილი Ø110 მმ
მაბინძრებელი საკანალიზაციო მილი Ø75 მმ
მაბინძრებელი საკანალიზაციო მილი Ø50 მმ
მაბინძრებელი საკანალიზაციო მილი Ø32 მმ
მაბინძრებელი საკანალიზაციო მილი Ø40 მმ
მაბინძრებელი საკანალიზაციო მილი Ø90 მმ
მაბინძრებელი საკანალიზაციო მილი Ø125 მმ
მაბინძრებელი საკანალიზაციო მილი Ø160 მმ
მაბინძრებელი საკანალიზაციო მილი Ø110 მმ
მაბინძრებელი საკანალიზაციო მილი Ø75 მმ
მაბინძრებელი საკანალიზაციო მილი Ø50 მმ
მაბინძრებელი საკანალიზაციო მილი Ø32 მმ
მაბინძრებელი საკანალიზაციო მილი Ø40 მმ
მაბინძრებელი საკანალიზაციო მილი Ø90 მმ
მაბინძრებელი საკანალიზაციო მილი Ø125 მმ
მაბინძრებელი საკანალიზაციო სისტემა
სანიტარული სველი წერტილი
ჩაშენებული ავეჯი
ჩაშენებული კარადა
ჩაშენებული ტუმბა
ჩაშენებული ნიშა
ჩაშენებული ნიშა
ჩაშენებული ნიშ

1 LV-22-MN

1 : 100


ფასადი Q-A'
ფასადი 7-1'
ფასადი 1'-7
ფასადი A'-Q
GA-WYA-EL_7-1'-A-W1202
GA-WYA-EL_A'-Q-A-MN203
GA-WYA-EL_Q-A'-A-MN204
GA-WYA-BS_3-3-A-MN303
GA-WYA-BS_1-1-A-MN351
GA-WYA-BS_1-1-A-MN301
GA-WYA-BS_2-2-A-MN302
80250
31700
14600
8250
ბინა 319
ბინა 318
ბინა 334
ბინა 333
ბინა 332
ბინა 331
ბინა 320
ბინა 321
ბინა 322
ბინა 323
ბინა 324
ბინა 325
ბინა 326
ბინა 327
ბინა 328
ბინა 329
ბინა 330
მაბეტონი საკაფებური სართულზე - 90.17 მ
მაბეტონი საკაფებური სართულზე - 87.07 მ
მაბეტონი საკაფებური სართულზე - 86.10 მ
მაბეტონი საკაფებური სართულზე - 65.32 მ
მაბეტონი საკაფებური სართულზე - 206.06 მ
მაბეტონი საკაფებური სართულზე - 38.27 მ
მაბეტონი საკაფებური სართულზე - 541.37 მ
მაბეტონი საკაფებური სართულზე - 431.00 მ
მაბეტონი წაკვეთზე არსებული ბლოკის მიწის ხაზამდე - 84.72 მ
მაბეტონი წაკვეთზე არსებული ბლოკის მიწის ხაზამდე - 32.15 მ
მაბეტონი წაკვეთზე არსებული ბლოკის მიწის ხაზამდე - 32.44 მ
მაბეტონი წაკვეთზე არსებული ბლოკის მიწის ხაზამდე - 32.15 მ
მაბეტონი საკაფებური სართულზე - 431.00 მ
ჩიხის სიგრძე
კიბეების მოედანი
ლიფტის შახტი
ლიფტის მანქანა
ლიფტის საბალანსო წონა
კიბეების ნაბიჯი
კიბეების ჭერი
კიბეების ფანჯარა
კიბეების ქვედა ნაბიჯი
კიბეების ზედა ნაბიჯი

1 LV-23-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო ვეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 23

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-24-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გოტბე დადიანის ქ. #32

სათაური :

Level 24

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-25-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 25

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-26-MN

1 : 100


ფასადი Q-A'
ფასადი 7-1'
ფასადი 1'-7
ფასადი A'-Q
GA-WYA-EL_7-1'-A-W1202
GA-WYA-EL_A'-Q-A-MN203
GA-WYA-EL_Q-A'-A-MN204
GA-WYA-BS_3-3-A-MN303
GA-WYA-BS_1-1-A-MN351
GA-WYA-BS_1-1-A-MN301
GA-WYA-BS_2-2-A-MN302
80250
31700
14600
8250
6640
6490
3360
1350
1870
6600
500
4000
2050
ხაზი 387
70.0
56.4 14.2
ხაზი 386
82.4
63.9 18.5
ხაზი 402
58.1
44.9 13.2
ხაზი 401
58.1
45.0 13.1
ხაზი 400
69.2
65.4 19.8
ხაზი 399
130.3
81.6 38.7
ხაზი 388
71.1
55.4 15.7
ხაზი 389
40.5
31.4 9.1
ხაზი 390
38.8
29.2 9.3
ხაზი 391
36.1
27.8 8.3
ხაზი 392
38.9
27.6 8.3
ხაზი 393
58.1
44.4 13.7
ხაზი 394
56.7
43.7 12.0
ხაზი 395
57.7
43.7 14.0
ხაზი 396
58.5
42.7 12.6
ხაზი 397
36.0
27.7 8.3
ხაზი 398
81.9
51.4 30.5
მაბეტონი საკიბატონო სიმაღლეზე - 90.17 მ
მაბეტონი საკიბატონო სიმაღლეზე - 87.07 მ
მაბეტონი საკიბატონო სიმაღლეზე - 65.32 მ
მაბეტონი საკიბატონო სიმაღლეზე - 86.10 მ
მაბეტონი საკიბატონო სიმაღლეზე - 431.00 მ
მაბეტონი საკიბატონო სიმაღლეზე - 541.37 მ
მაბეტონი საკიბატონო სიმაღლეზე - 206.06 მ
მაბეტონი ჩაქცეული არსებული ბლოკის მიწის ხაზიდან - 84.72 მ
მაბეტონი ჩაქცეული არსებული ბლოკის მიწის ხაზიდან - 38.44 მ
მაბეტონი ჩაქცეული არსებული ბლოკის მიწის ხაზიდან - 38.27 მ
მაბეტონი ჩაქცეული არსებული ბლოკის მიწის ხაზიდან - 32.15 მ
ნაკეცოვან ბლოკების განლაგება დანაგრილი ქერქებზე
ნაკეცოვან ბლოკების განლაგება დანაგრილი ქერქებზე
ნაკეცოვან ბლოკების განლაგება დანაგრილი ქერქებზე
ნაკეცოვან ბლოკების განლაგება დანაგრილი ქერქებზე
ჯამური მოთხოვნა 11.68 m
ჯამური მოთხოვნა 11.68 m
ჯამური მოთხოვნა 11.68 m
ჯამური მოთხოვნა 11.68 m
ჯამური მოთხოვნა 12.95 m
ჯამური მოთხოვნა 11.68 m
ჯამური მოთხოვნა 11.68 m
ჯამური მოთხოვნა 11.68

LV-26-ACC - მისაწვდომობის გეგმა - L26-L31

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N: 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 26

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : 1 : 100

ფორმატი : A0

თარიღი :

ნახაზის N : GA-WYA-BF-01-A-2201

რევ :

სტატუსი : **WIP**

1 LV-27-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 27

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 LV-28-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 28

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი : **WIP**

1 LV-29-MN

1 : 100


ფასადი Q-A'
ფასადი 7-1'
ფასადი 1'-7
ფასადი A'-Q
GA-WYA-EL_7-1'-A-W1202
GA-WYA-EL_Q-A'-A-MN204
GA-WYA-EL_A'-Q-A-MN203
GA-WYA-BS_3-3-A-MN303
GA-WYA-BS_1-1-A-MN351
GA-WYA-BS_1-7-A-MN301
GA-WYA-BS_2-2-A-MN302
31700
14600
8250
80250
6640
6490
1870
3360
1350
6600
500
4000
2050
მანძილი საკეტამდე სახანძრო 17.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 12.95 m
მანძილი საკეტამდე სახანძრო 11.04 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო 13.68 m
მანძილი საკეტამდე სახანძრო - 90.17 მ
მანძილი საკეტამდე სახანძრო - 87.07 მ
მანძილი საკეტამდე სახანძრო - 65.32 მ
მანძილი საკეტამდე სახანძრო - 86.10 მ
მანძილი საკეტამდე სახანძრო - 27.20 მ
მანძილი საკეტამდე სახანძრო - 206.06 მ
მანძილი წაქცევის არსებული ხელოვნ ბილიკის ბოლომდე - 84.72 მ
მანძილი წაქცევის არსებული ბილიკის ბოლომდე - 32.15 მ
მანძილი წაქცევის ბილიკის გასწვრივ - 38.27 მ
ნაკვეთზე ბილიკების გასწვრივ დაშვებული ხანძროს ავტომანქანის მოძრაობის ტრაექტორია

1 LV-30-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 30

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 LV-31-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Arch Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, გორგი დადიანის ქ. #32

სათაური :

Level 31

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N :	რევ :
GA-WYA-BF-01-A-2201	

სტატუსი :

WIP

1 RF-32-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 371 Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813351

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N:	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ვოლტე დადიანის ქ. #32

სათაური :

Level 32

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 RF-33-MN

1 : 100



Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა :

შენიშვნა:

Wei Yap Architects

Office Space #4, Level 3, 37, Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number - 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N: | **პროექტი :**

0000X — გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ვოლტე დადიანის ქ. #32

სათაური :

Level 33

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
1 : 100	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #34

1 : 40





თუჯი 11 საცხოვრებელი და საძინებელი ერთეულები "ა" ტიპის ბინა

ჯრომელტბეი მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიიი (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზთან დაშორებული ხელმისაწვდომი ძვლები



უკლის შესაგორებელი საშხაპის არმქონე ნაკვეთურის ხელმისაწვდი ძვლები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი
საშხაპის არ მქონე ნაკვეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობებისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-გამოწვევით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-მიწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : | **პროექტი :**

0000X — გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 05

მთავარი არქიტექტორი : LM/WY | **პროექტის ხელმძღვანელი :** GG

დახაზა : SP

მასშტაბი : As indicated | **ფორმატი :** A0 | **თარიღი :**

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #52

1 : 40





თბილი 11 საცხოვრებელი და საქინებელი ერთეულები "ა" ტიპის ბინა

ჯროექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიმე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზთან დაშორებულები
ხელმისაწვდი ძალები



უკლის შესაგორებელი საშხაის არმჭირე
ნაკეთურის ხელმისაწვდი ძალები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაის მქონე, ასევე ეტლის შესაგორებელი
საშხაის არ მქონე ნაკეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
საშხაის მქონე
ნაკეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
საშხაის მქონე
ნაკეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობებისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-გამოწვეით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-მიწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : | **პროექტი :**

0000X — გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 06

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
As indicated	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #70

1 : 40





თბილი 11 საცხოვრებელი და საქინებელი ერთეულები "ა" ტიპის ბინა

ჯრომელტბი მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიი (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარების ხმასალე



უნიტაზთან დამონტაჟებული
ხელმისაწვდი ძალები



უკლის შესაკორებელი საშხაის არმჭირე
ნაკეთურების ხელმისაწვდი ძალები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის საბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაის მქონე, ასევე ეტლის შესაგორებელი
საშხაის არ მქონე ნაკეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
საშხაის მქონე
ნაკეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
საშხაის მქონე
ნაკეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-გამოწვეით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-მიწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 07

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
As indicated	A0	

ნახაზის N : GA-WYA-BF-01-A-2201

რევ :

სტატუსი : **WIP**

1 ა ტიპის ბინა #88

1 : 40





თავი 11 საცხოვრებელი და საძინებელი ერთეულები "ა" ტიპის ბინა

ჯრომექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაჟიე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზთან დამონტაჟებული
ხელმისაწვდი ძალები



უკლის შესაგორებელი საშხაპის არმქონე
ნაკვეთურის ხელმისაწვდი ძალები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი
საშხაპის არ მქონე ნაკვეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობებისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-გამოწვევით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-მოწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 08

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : As indicated

ფორმატი : A0

თარიღი :

ნახაზის N :

რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #106

1 : 40





თავი 11 საცხოვრებელი და საძინებელი ერთეულები "ა" ტიპის ბინა

ჯრომექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიიე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ჟკეთუვი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზთან დაშორებული ხელმისაწვდი ძვლები



უკლის შესაგორებელი საშხაპის არმჭირე ნაკეთურის ხელმისაწვდი ძვლები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი საშხაპის არ მქონე ნაკეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი საშხაპის მქონე ნაკეთურის თავისუფალი სივრცე



ეტლის შესაგორებელი საშხაპის მქონე ნაკეთურის თავისუფალი სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე ახალი შენობა-ნაგებობებისთვის 304.3.2.1 (ბ) ვარინატი 2



თავისუფალი სივრცე კართან მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-გამოწვეით გაღება



თავისუფალი სივრცე კართან მანევრირებისთვის
-ანუკამიანი კარი
-წინიდან მისაწვდომი
-მიწოლით გაღება



უნიტაზთან მისადგომი თავისუფალი სივრცე



ხელსაბანთან მისადგომი თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, T'bilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 09

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : As indicated

ფორმატი : A0

თარიღი :

ნახაზის N :

რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #114

1 : 40





თავი 11 საცხოვრებელი და საძინებელი ერთეულები "ა" ტიპის ბინა

ჯროექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაჟიე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზთან დამონტაჟებული ხელმისაწვდი ძვლები



უკლის შესაგორებელი საშხაპის არმქონე ნაკვეთურის ხელმისაწვდი ძვლები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმისაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი
საშხაპის არ მქონე ნაკვეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობებისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანჯამიანი კარი
-ჩინიდან მისაწვდომი
-გამოწევით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანჯამიანი კარი
-ჩინიდან მისაწვდომი
-მოწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,@162, Tbilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 10

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : As indicated

ფორმატი : A0

თარიღი :

ნახაზის N :

რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #132

1 : 40





თავი 11 საცხოვრებელი და საძინებელი ოთახები "ა" ტიპის ბინა

პროექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიიე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ჩვეულებრივია და ნიჟარის სიმაღლე



უნიტაზით დამორებული ჩვეულებისაქცი ძალები



უკლის შესაგორებელი საშხაპის არმქონე ნაკვეთურის ჩვეულებისაქცი ძალები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი საშხაპის არ მქონე ნაკვეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი საშხაპის მქონე ნაკვეთურის თავისუფალი სივრცე



ეტლის შესაგორებელი საშხაპის მქონე ნაკვეთურის თავისუფალი სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე ახალი შენობა-ნაგებობებისთვის 304.3.2.1 (ბ) ვარინატი 2



თავისუფალი სივრცე კართან მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-გამოწევით გაღება



თავისუფალი სივრცე კართან მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-მოწოლით გაღება



უნიტაზთან მისადგომი თავისუფალი სივრცე



ხელსაბანთან მისადგომი თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,0162, Tbilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 11

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა : SP

მასშტაბი :	ფორმატი :	თარიღი :
As indicated	A0	

ნახაზის N : GA-WYA-BF-01-A-2201

რევ :

სტატუსი : **WIP**

1 ა ტიპის ბინა #150

1 : 40





თავი 11 საცხოვრებელი და საძინებელი ერთეულები "ა" ტიპის ბინა

პროექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიიე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებისა და ნიჟარის სიმაღლე



უნიტაზთან დამონტაჟებული ხელმისაწვდომი ძალები



უკლის შესაგორებელი საშხაპის არმქონე ნაკვეთურის ხელმისაწვდომი ძალები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი საშხაპის არ მქონე ნაკვეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი საშხაპის მქონე ნაკვეთურის თავისუფალი სივრცე



ეტლის შესაგორებელი საშხაპის მქონე ნაკვეთურის თავისუფალი სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე ახალი შენობა-ნაგებობებისთვის 304.3.2.1 (ბ) ვარინატი 2



თავისუფალი სივრცე კართან მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-გამოწევით გაღება



თავისუფალი სივრცე კართან მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-მოწოლით გაღება



უნიტაზთან მისადგომი თავისუფალი სივრცე



ხელსაბანთან მისადგომი თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,@162, Tbilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N :	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 12

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
As indicated	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #168

1 : 40





თავი 11 საცხოვრებელი და საძინებელი ერთეულები "ა" ტიპის ბინა

ჯროექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაჟიე (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქვეთავი 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზთან დამონტაჟებული
ხელმისაწვდი ძალები



უკლის შესაგორებელი საშხაპის არმქონე
ნაკვეთურის ხელმისაწვდი ძალები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი საშხაპის მქონე, ასევე ეტლის შესაგორებელი
საშხაპის არ მქონე ნაკვეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
საშხაპის მქონე
ნაკვეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობებისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-გამოწევით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-მოწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,@162, Tbilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N : 0000X

პროექტი : გრანდ ავენიუ დადიანი ბ ბლოკი
Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 13

მთავარი არქიტექტორი : LM/WY

პროექტის ხელმძღვანელი : GG

დახაზა : SP

მასშტაბი : As indicated

ფორმატი : A0

თარიღი :

ნახაზის N :

რევ :

GA-WYA-BF-01-A-2201

სტატუსი :

WIP

1 ა ტიპის ბინა #186

1 : 40





თავი 11 სამცხოვრებელი და საქინებელი ერთეულები "ა" ტიპის ბინა

ჯროექტში მოთხოვნის შესაბამისად "ა" ტიპის
10 ბინაა, ასევე ეტლის შესაგორებლიანი სამხაიი (სც-2 ჯგუფის საერთო რაოდენობის 2%)
გათვალისწინებული.
ქკეთები 1107.6.2.1.1 და "მისაწვდომი ეროვნული სტანდარტები"-ს შესაბამისად



სამოძრაო ზოლი



ხელსაბანებია და ნიჟარის სიმაღლე



უნიტაზით დაშორებული
ხელმისაწვდომი ძვლები



უკლის შესაგორებელი სამხაის არმქონე
ნაკეთურის ხელმისაწვდომი ძვლები

თავისუფალი სივრცეები "ა" ტიპის ერთეულში " მისაწვდომი ეროვნული სტანდარტები"-სმესაბამისად მისაწვდომი აბაზანა
ტუალეტები და მოწყობილობები შეესაბამება 1102.11 ქვეთავს.
ბინის სააბაზანო უზრუნველყოფილია, როგორც ეტლის შესაგორებელი სამხაის მქონე, ასევე ეტლის შესაგორებელი
სამხაის არ მქონე ნაკეთურის თავისუფალი სივრცეებით.



ეტლის შესაგორებელი
სამხაის მქონე
ნაკეთურის თავისუფალი
სივრცე



ეტლის შესაგორებელი
სამხაის მქონე
ნაკეთურის თავისუფალი
სივრცე



T-ს ფორმის მოსატრიალებელი სივრცე
ახალი შენობა-ნაგებობებისთვის 304.3.2.1
(ბ) ვარინატი 2



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-გამოწევით გაღება



თავისუფალი სივრცე კართან
მანევრირებისთვის
-ანჯამიანი კარი
-წინიდან მისაწვდომი
-მოწოლით გაღება



უნიტაზთან მისადგომი
თავისუფალი სივრცე



ხელსაბანთან მისადგომი
თავისუფალი სივრცე

Revision	Date	Description	Issued by	Issued to

GENERAL NOTES

1. Builders and/or Subcontractor to supply one sample each of the proprietary items, finished, samples materials and shop drawings for sign off prior to placement of Order, Fabrication or Construction.
2. Do not scale from this drawing - use figured dimensions.
3. A signed off original of this drawing is retained in Wei Yap Architecture Office for Verification purposes.
4. Information detailed in drawing revisions is for information only and may not be indicative of all changes made.
5. Builders and subcontractor to confirm set outs, levels, setback and critical dimensions on site including all services fixtures and fittings prior to and during the works. Notify Architects to any conflicts discovered prior to proceedings.

საორიენტაციო გეგმა:

შენიშვნა :

Wei Yap Architects

Office Space #4, Level 3, 37L Ilia Chavchavadze Avenue, Archi Tower,(G162, Tbilisi, Georgia.
info@weiyap.com | www.weiyap.com
Wei Yap Architects LLC
Identification Number : 405813151

COPYRIGHT © WEI YAP ARCHITECTS LLC

This work is copyright and cannot be reproduced or copied in any form or by any means without the written permission of Wei Yap Architecture (Wei Yap Architect LLC). Any license, express or implied, to use this document for any purpose whatsoever is restricted to the terms and of the agreement or implied agreement between Wei Yap Architecture and the instructing party. These drawings cannot be used for construction purposes within the written permission of Wei Yap Architecture.

დამკვეთი :

CLIENT NAME

პროექტის N :	პროექტი :
0000X	გრანდ ავენიუ დადიანი ბ ბლოკი Project Address: ქალაქი თბილისი, ცოტნე დადიანის ქ. #32

სათაური :

Level 14

მთავარი არქიტექტორი :	პროექტის ხელმძღვანელი :
LM/WY	GG

დახაზა :

SP

მასშტაბი :	ფორმატი :	თარიღი :
As indicated	A0	

ნახაზის N : | **რევ :**

GA-WYA-BF-01-A-2201

სტატუსი :

WIP



გასასვლელის კარი

გზა-კიბიდან/სადარბაზოდან გასასვლელი

წესებით გათვალისწინებული კარის ფრთის გაბარიტები
205X82 მმ. .
კარის ზომა ქვეთავი 1008.1.1-ით
განსაზღვრულზე ნაკლები არ უნდა იყოს

ცეცხლმედეგი კარი გაკეთდეს
"წესების "716;1008;1015
თავების მიხედვით, და ასევე
სპეციფიკაცია გაიარეთ მწარმოებელთან

1 ნიშნები / გასასვლელი კარი
1 : 10

პროექტის დასახელება

ობიექტის მისამართი
-

სიტუაციური სქემა

N

პირობითი აღნიშვნები

შენიშვნები

No.	რევიზია	თარიღი

დამკვეთი

საპროექტო ორგანიზაცია
არქი პრომოუშენი
ქ.თბილისი, ნ.ყიფშიძის ქუჩა №15
ტელ: 032 2 60 26 02

თანამდებობა	გვარი	ხელმოწერა
მთ.არქიტექტორი	ლ. მაღლაკელიძე	
არქიტექტორი		
დაამუშავა		
შეამოწმა		

ნახაზის სახელი
ნიშნები

ფურცელი
A151

ფორმატი	მასშტაბი
A1	1 : 10

თარიღი	სტადია	რევიზია
	SD	

C:\Users\a.gogoladze\Documents\210729_GDN-BA_Archi_detached_a.gogoladze.rvt

გასასვლელის განათებული ნიშანი



განათებული ნიშანი
თავშესაფრის ფართობთან მიმავალ კართან



ნიშანი ამობურცული სიმბოლოებით
და ბრაილით გზა-კიბის შესასვლელთან
და გარეთ გამავალ ყველა კართან



① ნიშნები
1 : 5

პროექტის დასახელება

ობიექტის მისამართი

-

სიტუაციური სქემა

N

პირობითი აღნიშვნები

შენიშვნები

No.	რევიზია	თარიღი

დამკვეთი

საპროექტო ორგანიზაცია

არქი პრომოუშენი

ქ.თბილისი, ნ.ყიფშიძის ქუჩა №15
ტელ: 032 2 60 26 02

თანამდებობა	გვარი	ხელმოწერა
მთ.არქიტექტორი	ლ. მაღლაკელიძე	
არქიტექტორი		
დაამუშავა		
შეამოწმა		

ნახაზის სახელი

ნიშნები

ფურცელი A152

ფორმატი A1

მასშტაბი 1 : 10

თარიღი

სტადია SD

რევიზია

C:\Users\a.gogoladze\Documents\210729_GDN-BA_Archi_detached_a.gogoladze.rvt

სასწრაფო სამედიცინო დახმარების საერთაშორისო სიმბოლო (სიცოცხლის ვარსკვლავი) განთავსდება ლიფტის ჩარჩოს ორივე მხარეს



ნიშანი განთავსდება ლიფტის გამოსაძახებელ ღილაკთან



1 ნიშანი 01
1 : 5

პროექტის დასახელება

ობიექტის მისამართი
-

სიტუაციური სქემა

N

პირობითი აღნიშვნები

შენიშვნები

No.	რევიზია	თარიღი

დამკვეთი

საპროექტო ორგანიზაცია

არქი პრომოუშენი

ქ.თბილისი, ნ.ჟიფშიძის ქუჩა №15
ტელ: 032 2 60 26 02

თანამდებობა	გვარი	ხელმოწერა
მთ.არქიტექტორი	ლ. მაღლაკელიძე	
არქიტექტორი		
დაამუშავა		
შეამოწმა		

ნახაზის სახელი

ნიშნები

ფურცელი A153

ფორმატი A1

მასშტაბი 1 : 5

თარიღი

სტადია SD

რევიზია

ნიშანი განთავსდება
გზა-ჯიბის საზღვრებში ჯარის მომიჯნავედ



ნიშანი განთავსდება
გზა-ჯიბის საზღვრებში ჯარის მომიჯნავედ



ნიშანი განთავსდება
გარე მისაწვდომ ავტოსადგომთან



ნიშანი განთავსდება
შიგა მისაწვდომ ავტოსადგომთან





1 ნიშნები
1 : 200

პროექტის დასახელება

ობიექტის მისამართი
.

სანჯეთირი სქემა

პირობითი აღნიშვნები

ცვლილებები

No.	რევიზია	თარიღი

დამკვეთი

საპროექტო ორგანიზაცია
არქი პროექტი
ქ.ქუთაისი, ნ.ლეონიძის კუთ. №15
ტელ: 032 2 40 26 02

თანამდებობა	გვარი	ხელმოწერა
მთარგმნელობრივი	ლ. გელოვანელიძე	
არქიტექტორი		
დამკვეთმა		
მეთვალყურე		

ნახაზის სახელი
ნიშნები

ფურცლის
A154

ფორმატი
A1

მასშტაბი
1 : 5

თარიღი

სტადია
SD

რევიზია

C:\Users\a.gogniashvili\Documents\21070?9_GDN-BIA_Archi_detached_a.gogniashvi.rvt

მოგესალმებით , გეგმებთან ერთად წარმოგიდგენთ, პროექტით განსაზღვრული გამოსაყენებელი შემავსებელი ბლოკის სპეციფიკაციას და ცეცხლმედეგობის ხარისხის სერტიფიკათს , რომელიც მოწოდებულია მწარმოებლის მიერ.

პროდუქტის მონაცემთა ცხრილი



ანაკრები ბლოკის წყობა

ტექნიკური ინფორმაცია	განსაზღვრება			
EN 771-4 - ის მიხედვით, კატეგორია I ბლოკის წყობა	სხვადასხვა ტიპის მზიდი და არამზი, ნებისმიერი დანიშნულების კედლები, მათ შორის ერთშრიანი, ღრუტანიანი, ტიხრები, საყრდენი და მიწის ქვეშა კედლები			
პროდუქტის ტიპი	არამზიდი			მზიდი
	G 2/0.35	**G 2/0.40**	**G 3/0.50**	**G 4/0.60**
სიმტკიცე კუმშვაზე, საშუალო სიდიდე	≥ 2,5 ნ/მმ^2	≥2,5 ნ/მმ^2	≥3,5 ნ/მმ^2	≥5,0 ნ/მმ^2
სრული მშრალი სიმკვრივე, საშუალო სიდიდე	350 კგ/მ^3	400 კგ/მ^3	500 კგ/მ^3	600 კგ/მ^3
თბოგამტარობა	0,087 ვტ/მკ	0,106 ვტ/მკ	0,13 ვტ/მკ	0,16 ვტ/მკ
თბოგამტარობა	0,09 ვტ/მკ	0,11 ვტ/მკ	-	-
საწყისი განივი სიმტკიცე ძვრაზე	-	-	-	≥ 0,30 ნ/მმ^2
ზომები **სიგრძე (± 1.5 მმ)**	200 მმ - 600 მმ			
სიგანე (± 1.5 მმ)	50 მმ - 400 მმ			
სიმაღლე (± 1 მმ)	200 მმ - 400 მმ			
ზომის ცდომილება	TLMB			
საძირკვლის ზედაპირის სიბრტყე	≤ 1 მმ			
ზედაპირის პარალელური სიბრტყეები	≤ 1 მმ			
წყლის შეწოვა	NPD			
ორთქლის შეღწევადობა μ	5/10			
ტენიანობის ცვალებადობა (კუმშვა)	< 0,2 მმ/მ			
ცეცხლმედეგობა	A1 კლასი, არა აალებადი			
გამძლეობა (ყინვა/ლღობა)	დაუცველი ზედააპირები უნდა შეიფუთოს.			
ტევადობა	დასაწყობდეს სამი ერთმანთზე დალაგებული პალეტი			
მიწოდება	მიწოდება გადასახვევი პოლიეთილენით/ელასტიური შეფუთვით			

TÜrk Ytong Sanayi A.Ş.

აიდინევლერი, ინონუს გამზირი. გოქჩეს ქ. No: 3 მალტაპე. 34854 სტამბული / თურქეთი

ტელ. +90 (216) 396 66 00 · fax +90 (216) 396 19 61

www.ytong.com.tr

სამუშაოს დეკლარირება	**90000005**

1.	პროდუქტის ტიპის უნიკალური საიდენტიფიკაციო კოდი	**TYA/T/G2-0,40; TYA/IB/G2-0,40**

2.	განკუთვნილი გამოყენება ან გამოყენებები	სხვადასხვა ტიპის არამზიდი ნებისმიერი დანიშნულების კედლები, მათ შორის ერთშრიანი, ღრუტანიანი, ტიხრები, საყრდენი და მიწის ქვეშა კედლები

3.	მწარმოებელი	**TÜrk Ytong Sanayi A.Ş. - Antalya Fabrikası** **Organize Sanayi Bolgesi 1. Kısım Akdeniz Bulvarı Cad. No: 4 Dosemealti / ANTALYA**

4.	შესრულების თანმიმდევრულობის შეფასებისა და შემოწმების სისტემა ან სისტემები	სისტემა 2+

5.	შესაბამისი სტანდარტი და ორგანო	**TS EN 771-4** **Kliwa GmbH Niederiassung MPA berlin-Brandenburg, Gebaude 10.6 Voltastrabe 513355 Berlin, NB 0770**

სამუშაოს დეკლარირება	**90000005**

6.	დეკლარირებული სამუშაო	Ytong G2/0.40	
	ზომები, სიგრძე	600 მმ ± 1.5 მმ	
	ზომები, სიგრძე	50 400 მმ ± 1.5 მმ	
	ზომები, სიგრძე	250 მმ ± 1.0 მმ	
	ფორმა	შესაძლებელია მოთხოვნით	
	ზომის შემცირება		
	კატეგორია	TLMB	EN 771-4
	საძირკვლის ზედაპირის სიბრტყე	≤ 1,0 მმ	EN 772-20
	ზედაპირის პარალელური სიბრტყეები	≤ 1,0 მმ	EN 772-16
	სიმტკიცე კუმშვაზე, საშუალო სიდიდე	2.50 ნ/მმ^2 კუბური ნიმუში	EN 772-1
	ბმის განივი ძვრის სიმტკიცე	NPD	EN 998-2: EK C /დანართი C
	სრული მშრალი სიმკვრივე, საშუალო სიდიდე	400 კგ/მ^3	EN 772-13
	ცეცხლმედეგობა	A1	EN 13501-1
	გამძლეობა (ყინვა/ლღობა)	დაუცველი ზედაპირები უნდა შეიფუთოს.	-
	ორთქლის შეღწევადობა μ	5/10	EN 1745: ჩანართი. A10
	თბოგამტარობის კოეფიციენტი	≤ 0,1060 ვტ/მკ	EN 126664
	ზომის სტაბილურობა (კუმშვა)	≤ 0,2 მმ/მ	EN 680
	სახიფათო ნივთიერებები	უსაფრთხოების მონაცემების დანართი მოთხოვნით	

7.	ზემოთ მოცემული პროდუქტის შესრულება შეესაბამება დეკლარირებულ სამუშაოს. შესრულების ეს დეკლარაცია სამშენებლო პროდუქტების რეგულაცია (305/2011/AB) შესაბამისადაა და გაიცემა ზემოთ მითითებული მწარმოებლის პასუხისმგებლობით.	M. Murat SÜMER Genel Müdür Yardımcısı (Teknik) Deputy General Manager (Technical) İstanbul, 07.10.2020